BAC-5051E

Model: BAC-5051E



If controllers are to be networked together via MS/TP, turn ***ON*** EOL switch on the controllers at both physical ends of the network. Connect shield to earth ground at only one point.

© 2020 KMC CONTROLS, INC.

19476 INDUSTRIAL DR.
NEW PARIS, IN 46553
PHONE: 574.831.5250
FAX: 574.831.5252
kmccontrols.com

DRAWING TITLE: BAC-5051E		
CREATION DATE:	6/4/2015	FILENAME: BAC-5051E_E
REVISION DATE:	4/1/2020	REVISION: UPDATED LOGO