



In wiring expansion modules, turn **ON** EOL switch on the controllers at both physical ends of the network. Connect shield to earth ground at only one point.

**NOTES:**

1. See [www.kmccontrols.com](http://www.kmccontrols.com) for accessories and additional details.